


# BACnet CONFORMANCE CERTIFICATE



**No. BTL-30257**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.14. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 14.0 and the BTL Testing Policies, see Test Report number VG 2017\_15120 of MBS.

Product name (B-BC)
<b>EY-modulo 5 Room Automation Controller</b>
<b>Model(s)* EY-RC504Fxxx, EY-RC505Fxxx</b>
Software version
<b>V3.1.0b753</b>
Vendor
<b>SAUTER HeadOffice (Fr. Sauter AG)</b> <b>Im Surinam 55</b> <b>4016 Basel, Switzerland</b>

\* where x is according to listing information

This certificate is valid until **31-Mar-2023**.

**12-Feb-2018**

Date of Initial Certification

Dipl.-Ing. G. Weinmann  
Head of Certification Body