

BACnet CONFORMANCE CERTIFICATE



No. BTL-31109

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.24. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.1 and the BTL Testing Policies, see Test Report number VG 2022_1014559 of MBS.

Product name (B-RTR,B-BBMD,B-SCHUB)
modulo 6 BACnet Router and SC-Hub
Model(s) EY6RT30F001
Firmware version
V1.0.1b3845
Vendor
Fr. Sauter AG
Im Surinam 55
4058 Basel, Switzerland

This certificate is valid until **31-Mar-2029**.

09-Jan-2024

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body